Lot-5

		for Procurement of Rac	hator for	HVAC	1 Mandatan daguments	
Mandatory Documents		xvii. ATL xviii. NTN Registration xix. GST Registration xx. Last year Income Tax Return. xxi. Last year Sales tax Return. xxii. Latest three years Bank statement. xxiii. Affidavit on stamp papers duly attested regarding black listing other condition as per		Bids without Mandatory documents shall not consider for evaluation.		
S. No.	Parameters	specimen on page-4 xxiv. Certificate that 2% attached with Finan Detail / Supporting Documents	CDR is	Total	Remarks	
1	Past performance (Last one year) as per signed Bid form 4	Major institution served: i. No institution served ii. 1 to 2 iii. 3 to 5 iv. More than 5	0 5 10 15	Marks 15	Institutions include Government departments and Private hospitals of 50 or more beds and registered with HRA KPK or Equivalent Registering Body.	
2	Market experience in quoted items	i. 1 to 3 years ii. 4 years or more	5 10	10	As a minimum requirement, during any of the last three years, he must have completed at lest One contract involving the supply, of similar Goods and each at lest 50% of comparable scale.	
3	Product Sample	Goods samples will be examined & accepted by the Technical & Evaluation Committee as per the following parameters: • Consistency in quality • Durability i. Excellent ii. Good iii. Unsatisfactory 0			Product that 100% comply with the advertised specifications will be considered for evaluation. NOTE: Warranty Period One year is Mandatory.	

Total marks: 40

Qualifying marks: 70% (28) and above, the financial bids of technically accepted bidders will be opened publicly at a time to be announced by the Procuring Agency and the financial bids found technically non-responsive shall be returned un-opened to the respective Bidders. Lowest priced bid from the technically qualified bidder will be accept

MAINTENANCE & ENGINEERING DEPARTMENT AYUB TEACHING HOSPITAL ABBOTTABAD

SPECIFICATIONS FOR RADIATORS:-

- The radiators are to be of steel panel type. These shall be manufactured
 according to the requirement of international standard and subject to a
 pressure test. The radiators shall be constructed from cold reduced steel
 with proper thickness.
- Connection bosses shall consist of tapings welded to the back panel. No site bushing being permitted in any circumstances. The return and air lock is to be recessed within the radiator length.
- Supports for radiators shell in all cases be of a type not materially visible
 from the front and shall take the form of a slotted attachment welded to
 the rear panel face with concealed bracket fittings.
- Enclosure shall be made from high grade steel, phosphatized and leaks.
 Finished in prime coat for protection against corrosion.

CERTIFICATION: INTERNATIONAL STANDARD CERTIFICATION FROM REGULATORY / PROFESSIONAL BODIES.



BOOK OF QUANTITIES RADIATORS FOR HVAC SYSTEM AYUB TEACHING HOSPITAL ABBOTTABAD

S.No	Description	Size	Qty	Rate	Amount
1	Supply, fixing, of Radiators Duly Supported by Catalogue, Brochure etc complete in all respect as per specification and instruction of Engineer incharge.	600x900mm	100		
2	Supply, fixing, of Radiators Duly Supported by Catalogue, Brochure etc complete in all respect as per specification and instruction of Engineer incharge.	600x1800mm	200		

Issued to	
Vide deposit receipt No:	
	Name Address of Firm:
	Stamp

100m