

**MAINTENANCE AND ENGINEERING DEPARTMENT**  
**AYUB TEACHING HOSPITAL (MTI) ABBOTTABAD**

**BOQ FOR THE PROVISION OF POWER SUPPLY CABLE AND DISTRIBUTION BOARD FOR X-RAY MACHINES**  
**ROOM NO-2 & ROOM NO-4 AT RADIOLOGY.**

S.No	Description	Qty	Cost	Total
<b>X-Ray Machine Room No.2 &amp; 4</b>				
1.	Cable 4 Core 50 mm copper conductor 1000 volt grade unarmed for 2 No X Ray Machine from electric switch room to machine (Pakistan Cable/Equaling)	135 Meter		
2.	Distribution Board Size 24"x 36"x 1=16 Swg Powder coated lock able with 200 Amp copper bus bar complete in all respect	02 Nos		
3.	Magnetic contractor 100 Amp 220 coil volt Schneider/Equaling Imported	02 Nos		
4.	MCCB.75-A,T,P.Schneider/Equaling Imported	02 Nos		
5.	Under volt & Over volt Relay Schneider/Equaling Imported	02 Nos		
6.	Volt Meter Digital 0-500 Volt Imported	06 Nos		
7.	Bush Button ON/OFF Best Quality	02 Nos		
8.	Control Fuse Rotary 5 Amp Porcelain	06 Nos		
9.	Circuit Breaker 04- Pole 75-Amp Schneider/Equaling Imported	02 Nos		
10.	Earth Rod Wapda Specification for Preparation separate earth for 2 No X-Ray Unit	08 Nos		
11.	Bare Conductor Copper for Earth 70 mm	140 Meter		

**Deputy Director Maintenance**

**Assistant Engineer (E)**

Issue to

\_\_\_\_\_

\_\_\_\_\_

CDR NO \_\_\_\_\_

## **Document must be attached with Tender**

1. Status on ATL
2. Income Tax Registration
3. GST Registration/Last Year Return Certificate
4. One Year Bank Statement
5. Affidavit on stamp paper duly attested regarding black listing and other conditions as per provided specimen in bid document.
6. Past Experience in relevant Field work

## **Terms And condition**

1. The Terms & Conditions mentioned in the advertisement notice are part & partial of tender documents.
2. The Warranty of the assigned work will be one year after inspection of the work by institution inspection Committee in case any defect developed in the system it will be clear by contractor on his risk and Cost.
3. The contractor will bound to complete the work as per specification mentioned in the tender document.
4. The tender should be Single Stage single envelope bases.
5. The cable test report from the manufacturing must be required before inspection of the work
6. Tender shall be valid for 90 days.
7. The Tender shall be submitted in sealed envelope with the name of the work written on the envelopes & shall be send through courier or register dak.
8. 2% bid security for the work in shape of a call deposit from any scheduled bank of Pakistan in the name of the Hospital Director Ayub Medical Teaching Institution Abbottabad must be attached with the tender.
9. Tenders which do not fulfill any or all of the condition or incomplete in any respect are liable to be rejected.
10. Contractor cannot sublet the whole tender or any part of the tender to other parties. If found so the tender will be cancelled and call deposit as well as security will be forfeited.
11. In case of false information in the tender, the tender will be rejected with forfeit of CDR

**BOQ FOR THE REPAIR/REWINDING OF TRANSFORMERS.**

S.No	Description	Quantity	Rate	Total
<b>Sewage Treatment Plant 200-KVA Transformer.</b>				
01.	Rewinding/Replacement High Tension Coil 200-KVA with 03-Month Warranty.	01-Coil		
02.	Rewinding/Replacement Low Tension Coil 200-KVA with 03-Month Warranty.	01-Coil		
03.	Supply / Pouring / Dehydration Transformer Oil	200-Litters		
04.	Repair of 200-KVA Transformer Body/ Labor Charges /Testing Commission.	01-Job		
<b>MCHC 630-KVA Transformer.</b>				
05.	Rewinding/Replacement High Tension Coil 630-KVA with 03-Month Warranty.	01-Coil		
07.	Rewinding/Replacement Low Tension Coil 630-KVA with 03-Month Warranty.	01-Coil		
08.	Supply / Pouring / Dehydration Transformer Oil	100-Litters		
09.	Labor Charges /Testing Commission.	01-Job		
10.	Supply / Fixing HRC Tubular Fuse with Striker Pin 12.5 Amp, 11-KV (Imported)	03-Nos		
<b>AMC Rest House 100-KVA Transformer.</b>				
11.	Rewinding/Replacement High Tension Coil 100-KVA with 03-Month Warranty.	02-Coil		
12.	Rewinding/Replacement Low Tension Coil 100-KVA with 03-Month Warranty.	01-Coil		
13.	Supply / Pouring / Dehydration Transformer Oil	30-Litters		
14.	Labor Charges /Testing Commission.	01-Job		
<b>TUBE WSL NO3,200-KVA Transformer.</b>				
15.	Rewinding/Replacement High Tension Coil 100-KVA with 03-Month Warranty.	02-Coil		
16.	Rewinding/Replacement Low Tension Coil 100-KVA with 03-Month Warranty.	01-Coil		
17.	Supply / Pouring / Dehydration Transformer Oil	30-Litters		
18.	Repair of 100-KVA Transformer Top Cover/ Labor Charges /Testing Commission.	01-Job		

**Deputy Director Maintenance**

**Assistant Engineer (E)**

**Issue to:**

M/S \_\_\_\_\_

\_\_\_\_\_

CDR NO \_\_\_\_\_

## **Document must be attached with Tender**

1. Status on ATL
2. Income Tax Registration
3. Three Year Bank Statement
4. Affidavit on stamp paper duly attested regarding black listing and other conditions as per provided specimen in bid document.
5. Past Experience in relevant Field work at least Three Year.

## **Terms And condition**

1. The Terms & Conditions mentioned in the advertisement notice are part & partial of tender documents.
2. The Firms must be registered with Khyber Pakhtunkhwa Revenue Authority.
3. The Warranty of the assigned work will be Six Months after inspection of the work by institution inspection Committee in case any defect developed in the system it will be clear by contractor on his risk and Cost.
4. The contractor will bound to complete the work as per specification mentioned in the tender document.
5. The tender should be Single Stage single envelope bases.
6. Tender shall be valid for 90 days.
7. The Tender shall be submitted in sealed envelope with the name of the work written on the envelopes & shall be send through courier or register dak.
8. 2% bid security for the work in shape of a call deposit from any scheduled bank of Pakistan in the name of the Hospital Director Ayub Medical Teaching Institution Abbottabad must be attached with the tender.
9. Tenders which do not fulfill any or all of the condition or incomplete in any respect are liable to be rejected.
10. Contractor cannot sublet the whole tender or any part of the tender to other parties. If found so the tender will be cancelled and call deposit as well as security will be forfeited.
11. In case of false information in the tender, the tender will be rejected with forfeit of CDR