



AYUB TEACHING HOSPITAL

ABBOTTABAD

Standard Bidding Document

For

**SUPPLY, INSTALLATION AND COMMISSIONING OF
DRINKING WATER CHILLER AND REVERSE
OSMOSIS SYSTEM AT AYUB TEACHING HOSPITAL
ABBOTTABAD**

FOR THE YEAR 2022-2023

ADVERTISEMENT

Ayub Teaching Hospital

S.NO	Description	Detail
1	Bid reference number	AYUB Teaching Hospital- Abbottabad Tender/2022-23
2	Name of Client & source of funds	MTI/ ATH/.
3	Name of Goods	SUPPLY, INSTALLATION AND COMMISSIONING OF DRINKING WATER CHILLER & REVERSE OSMOSIS SYSTEM AT AYUB TEACHING HOSPITAL ABBOTTABAD
4	Commencement date of provision of Bidding Document Closing date of issuance of tender documents	As per advertisement notice.
5	Bidding for Selective Items	Yes
6	Bidding procedure	Single Stage ONE Envelop Procedure
7	Clarification(s) on Bidding Documents	Ayub Teaching Hospital Abbottabad
8	Language of bid	English
9	Bid Price	Bid Price shall be inclusive of all duties and all Govt Taxes.
10	Currency of Bid	PAK Rupees

Ayub Teaching Hospital

11	Amount of Bid Security / Earnest Money	<i>The Bidder shall furnish, as part of its bid, a Bid Security as per advertisement in the name of Hospital Director, ATH, Abbottabad.</i>
12	Last date and time for receipt of bidding document	As per advertisement notice Through registered post or courier service by hand tenders will not be accepted.
13	Date, time and venue of opening of technical bids	As per advertisement notice
14	Duration of Contract	Framework contract
15	Bid Validity	90 Days

TERMS AND CONDITIONS.

Sealed and postal tenders are invited for the following to Ayub Teaching Hospital Abbottabad for the Year 2022-23 from the eligible firms as per bidding documents.

1. Active Status on ATL
2. NTN Registration.
3. GST Registration.
4. Last year Income Tax.
5. Last year sale tax return.
6. Last three years Bank Statement.
7. Affidavit on stamp paper duly attested regarding not blacklisting and not in litigation with any Govt /Semi Govt: departments.
8. The 2 % of bid quoted priced CDR must be attached with the bid
9. The firm must be manufacturer or sole agent or authorized distributor are eligible for participating in the bidding process.
10. Two years warranty period of chiller.
11. A complete profile of the firm must be attached showing the execution of all civil, water supply gas etc executed work along with work order and completion certificates of work from the department/agencies must be attached along with bid.
12. Subletting of contract is not allowed
13. The firm bound to train ATH staff for operation and maintenance.
14. The firm provides two sets of manual/booklet of the chiller to engineer incharge.
15. Rate Quoted must be in printed form: hand written quoted rate and cutting /over writing will be rejected at the time of opening of bid.
16. Tender will be received and opened as per advertisement notice.
17. The KPPRA standard bidding documents for small goods/ General Condition of the contract are part of this bidding documents.
18. Tender will be single stage single envelop basis.
19. The tender envelops must be sealed and clearly Marked as “Name of Tender” which shall be addressed to Hospital Director Ayub Teaching Hospital.
20. The bidding documents fee Rs. 1500/- is non-refundable.
21. Incomplete tender will not be accepted and will stand cancelled.
22. Conditional tender will not be accepted and will stand cancelled.
23. The price must be quoted as per Tender list on letter head pad of the firm.

Ayub Teaching Hospital

24. If the contractor fail to complete the project as per work order and within stipulated time specified in the schedule of requirement the penalty @ 0.5% of the total project value for each 14 days of delay shall imposed not exceeding 10 % of the total project cost.
25. The payment will be made after receipt/acceptance of completion of testing and commissioning in accordance with the approved specification within 28 days from the receipt of invoice and inspection report satisfactory report of engineer incharge.
26. No advance payments will be made under any circumstance, No substandard material will be accepted and will be return to contractor at his own risk and cost.
27. The competent authority can reject the tender as per KPPRA rules.
28. Tender will be considered according to relevant existing KPPRA rule or every amendment notify by the KPPRA authority during bidding process
29. The quoted rates should be inclusive of all Govt taxes applicable time to time & any additional charges imposed by the Govt. Moreover the Hospital authority shall not pay any charges on account of transportation /installation/commissioning etc.
30. Proposals shall be submitted in English language
31. Each page of the tender shall be signed by the bidder.
32. The institutional blacklisting manual is part of this bidding document.

HOSPITAL DIRECTOR
Ayub Teaching Hospital

**THE LIST OF REQUIRED ITEMS WITH
QUANTITY IS ATTACHED HEREWITH AS
PART OF TENDER DOCUMENTS**

**MEDICAL TEACHING INSTITUTION
AYUB TEACHING HOSPITAL**
Maintenance & Engineering Department



BILL OF QUANTITIES FOR SUPPLY INSTALLATION OF WATER CHILLER / REVERSE OSMOSIS SYSTEM AT A&E ATH ATD.				
S.No	Item Description	Unit Rate (Rs.) Including installation Price (A)	Quantity (B)	Total Amount (Rs.) (AXB)
01.	<ul style="list-style-type: none"> ➤ 5 hp SS Air Cooler Chiller dual Compressor unit which maintains water temperature from 35°C to 5°C ➤ Cooling Capacity 500 lt/hr ➤ Stainless Steel Body Structure/Material ➤ Compressor 5 hp, 3 phase, 400V (Imported) Compressor Condition New ➤ Shell and Tube Water Cool Evaporator of SS 304 grade with proper insulation ➤ Condensing Fan motors (Imported) 2-Nos ➤ Air Cool Condenser copper pipe & aluminum fins ➤ Circulation pump of 1 hp (Size 1" by 1") ➤ Fully Automatic control panel with all safety components ➤ Gas & Safety valves ➤ Low/High Pressure Gauges and Switches ➤ Gas Filter Dryer ➤ Refrigerant R22 ➤ 04 chilled water tap & 04 fresh water tap ➤ Complete in all respect 		01 Set	
	<ul style="list-style-type: none"> ➤ Reverse osmosis system capacity 1000lt/hr With Brand New High Pressure Pump ➤ Reverse osmosis system capacity 1000lt/hr With new (Imported) High Pressure Pump ➤ PVC Water Tanks (Food Grade) 2000 L (Qty 1) 1000 L (Qty 2) ➤ Complete set installation at site including Machinery Transportation Charges ➤ External Upvc Fitting of whole system ➤ PH online meter ➤ Iron meter ➤ Nitrite meter, Alkalinity meter ➤ Complete in all respect. 		01 Set	
TOTAL AMOUNT (RS.):				
Note: - All the taxes will be deducted as per Government rules.				

Contractor Firm Name
With Seal

26/8/22

26/8/22