


| S. No | Item Description | Price |
|-------|---|---------|
| 1 | Liquid Medical Oxygen M ³ Supply of Liquid Medical Oxygen to Ayub Teaching Hospital Abbottabad(Liquid Oxygen will be taken in KG & bill will be in NM3. | Per NM3 |

Compressed Medical Gases

| | | |
|----|--|-----------|
| 2 | Refilling of Medical Oxygen Cylinder Size 240cft on 2000psi | PER CFT |
| 3 | Refilling of Medical Oxygen Cylinder Size 220cft on 2000psi | |
| 4 | Refilling of Medical Oxygen Cylinder Size 200cft on 2000psi | |
| 5 | Refilling of Medical Oxygen Cylinder Size 100cft on 2000psi | |
| 6 | Refilling of Medical Oxygen Cylinder Size 98cft on 2000psi | |
| 7 | Refilling of Medical Oxygen Cylinder Size 48cft on 2000psi | |
| 8 | Refilling of Medical Oxygen Cylinder Size 24cft on 2000psi | |
| 9 | Refilling of Compressed air Cylinder Size 240cft on 2000psi | |
| 10 | Refilling of Compressed Nitrogen Cylinder Size 240cft on 2000psi | |
| 11 | Refilling of Compressed Air Cylinder Size 240cft on 2000psi | |
| 12 | Refilling of N2O Cylinder Size 16200 Liters | |
| 13 | Refilling of Helium Cylinder | Per CFT |
| 14 | Refilling of N2O Cylinder Size 1620 Liters | Per Liter |
| 15 | Refilling of CO2 Gas | Per KG |
| 16 | Cylinder valve for Oxygen ,Nitrogen ,Air ,Nitrous Oxide imported | Each |
| 17 | Hydraulic Testing of Cylinder | Each |
| 18 | Painting of Cylinder | Each |


 16/6/23
 Boiler Engineer

TERMS & CONDITION (for successful bidder)


This agreement is made at Ayub Teaching Hospital on _____ between successful bidder through _____ CNIC No. _____ Designation _____, Official Address _____, hereinafter referred as 1st Party, which expression shall unless repugnant to the context mean and include this heirs, executors, administrators, successors, and assigns.

AND

The Hospital Director Ayub Teaching Hospital (MTI), Abbottabad (here in after referred as 1st Party which expression shall unless repugnant to the context mean and include its successors-in-interest and assigns.

Whereas 2nd Party is a Prominence Company Manufacturer of Medical Gases and in consequence of tender notice and quotation submitted by the 2nd Party which was duly compared and negotiated with the purchase committee is willing to supply Medical Gases as mentioned below and the 1st Party being the competent authority is agreed to accept the Medical Gases on the following terms and condition: -

1. That the 2nd Party shall abide by the order of 1st party and authorities under whom it may from time to time be placed by the 1st party or supervision of supply.
2. In continuation of supply (Medical Gases) made by the 2nd Party under the agreement the 1st party shall on the representation of the bills pay as per tender documents rates accepted by the 1st party.
The rates accepted shall be valid till 30.06.24 or till finalization of next tender. In case of any ban on institute for new-tendering/New issuing of letter of award from Provincial Government, 2nd party will not terminate supply Medical Gases to hospital in best interest of Patient. In such case if happen or tried to black mail hospital, 2nd party will be black listed all over Pakistan and security will be forfeited.
4. Hospital Director can terminate the contract any time keeping in view financial aspects of fiscal years, mean while 2nd party will keep on supply till finalization of tender.
5. The 2nd party shall be responsible for the supply throughout the mentioned period without any break. In case of any fault/service/repair in the plant required, the 2nd party will inform the 1st party in advance and also arrange Liquid Oxygen from alternate source for hospital.
6. Liquid Medical Oxygen (O2 No. VIE Tank 15000 liter each. One for ATH & one for MCHC) with evaporating coil and upstream system and Telemetry System will be installed by the 2nd party & would remain the property of the 2nd party. At present Liquid Oxygen (VIE TANK 10,000 & 5000 lit qty O2Nos) with evaporating coil and upstream system installed at Ayub Teaching Hospital Abbottabad will be returned to the 2nd Party i.e. (_____) on


26/9/23

Cancellation of contract agreement by 1st party giving one-month prior notice.

The 2nd party shall be responsible for the service of Liquid Oxygen (VIE TANKS) with complete calibration of pressure gauges / safety valves installed at Ayub Teaching Hospital Abbottabad on yearly basis and 2nd party shall be responsible for security and safety of VIE TANK and accessories.

The bills will be paid by 1st party to the 2nd party at an early date within Fifteen Days on submission of bills.

The 2nd party will refill the minimum 100 Cylinder or as per requirement of the hospital on daily basis and the 1st party staff will be responsible to arrange the empty cylinders stock for refilling. Telemetry System installed by 2nd party and will be monitored 24/7, however its monitoring access will also be provided to Hospital Oxygen Plant Engineer, as per their demand and provision of required Monitors and network system in required place.

The 2nd Party will be responsible to fill the VIE Tank before level reaches to 50%, and 1st Party will be responsible to monitor the VIE Tank Level 24/7 and will inform the 2nd party timely.

In case of any shut down or maintenance / trouble shooting required in the VIE Tank, 2nd party will carry out the repair work and tanker will be arranged as back up supply, however compressed cylinder must be arranged /available for any emergency in the Hospital.

13. Purity Certificate must be provided with quarterly supply of Liquid Medical Oxygen.
14. Operational, Maintenance and safety training on VIE Tank and Cylinders Handling will be provided to ATH Staff as and when required basis throughout the contract period.
15. The prices of Compressed Gases / Liquid Oxygen are inclusive of all government imposed Tax.
16. The 2nd party shall indemnify the 1st party in case of any accident occurred due to shortage of Medical Gases and will arrange liquid oxygen from alternate source to hospital.

Engr. Ahsen Aziz Khan,
Manager Maintenance.

Engr. Ameen Ullah Khan,
HOD (E)

Addition in Technical evolution criteria for Medical Gas (Liquid) supply

| | | | | |
|-----------------------------------|---|--|-------------------------------|---|
| <p>Mandatory Documents</p> | <p>The vender must be original manufacturer of Medical /Oxygen Gas (Liquid) in Pakistan and certificate on judicial stamp paper to the same effect must be provided</p> <p>Active statues on Active Tax payer List of FBR</p> <p>GST certificate</p> <p>NTN certificate</p> <p>Income Tax Registration</p> <p>Last year Income Tax Return</p> <p>Last year Sales Tax Return</p> <p>Last 03 years bank statement & audit reports by external auditor</p> <p>Certificate that CDR is attached with financial bid</p> <p>Affidavit on stamp paper duly attested regarding black listing and other conditional as provided specimen in bid documents.</p> <p>Registration with Respective Departments</p> <p>100% Compliance With Purchaser Specification</p> <p>Warranty With Parts as per Bid Documents</p> | <p>Bids without Mandatory document shall not be considered for evaluation</p> | | |
| <p>S/No</p> | <p>Parameters</p> | <p>Detail/Supporting Documents</p> | <p>Maximum Marks</p> | <p>Remarks</p> |
| <p>1</p> | <p>Physical resources</p> | <p>Established office within 200Km from purchase: 3</p> <p>Established office beyond 200 Km from purchaser: 2</p> <p>List of relevant qualified/experienced employees</p> <p>List of relevant tools for quoted items</p> | <p>03</p> <p>03</p> <p>03</p> | <p>Details with supporting documents must be attached</p> |

| | | | |
|---|--|---|---|
| 2 | Past Performance of last one years (satisfactory certificate to be attached along with supply order) | 01 marks per institute. Maximum 05 marks | 05 |
| 3 | Market Experience | 1 Mark Per Year. Maximum 05 Marks. | 05 |
| 4 | Manufacturers performance certificate (i.e. ISO certificates) | 02 marks per certificate total 05marks | 06 05 |
| 5 | Manufacture /Dealership | 1. Original Manufacture (5) 2. Authorized Dealer (3) 3. General Supplier (1) | 05 |
| 6 | Warranty | 1. 01 Year beyond warranty with parts: (2) 2. 02 Year beyond asked warranty with parts.(4) 3. 03 Year beyond asked warranty with parts (6) | 06 05 06 |
| 7 | Running Cost of Quoted Item. (Economical=10, Medium=7, Costly=3, Very Costly=0) | 1. List with Cost of consumable items of Quoted Item. 2. List with Cost of Replaceable accessories of quoted item. 3. Charges not covered by warranty. 4. Expected Numbers/ duration of services/ test/ procedures with brand new accessories. | 4 Concerned Engineer & End user will calculate this cost |
| 8 | Products | 1. 3 rd Part certificate of sample. 2. Telemetry system. 3. 3 rd Party certificate of Pressure Tank. 4. Duplex System. 5. Online monitoring Remote access | 10 |



Senior Engineer